



BRUHAT BENGALURU MAHANAGARA PALIKE

Office of the Assistant Health Officer, South Zone, Malleshwaram, Bengaluru.

Annexure C

APPENDIX – XIII

No. BOMP/SHN/ASH/PR/9-2024-25

Dated: 16/04/2024

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is Certified that an inspection team headed by Bathiyappa Assistant Health Inspector (Name of Officers with designation) from Assistant Health Inspector, B.B.M.P. Chamarajpet, Bengaluru (Name of Department/ Office) inspected the Royale Concorde International School, No.31, 1st Main Road, Chamarajpet, Bengaluru-560018 (Name & Address of the School) on 12/04/2024 (date of inspection), checked the water test report vide Report No.SLNTL2400400015, dated-04/04/2024 submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

The above is valid for a period of 5 Year.

Bathiyappa 16/4/24

Asst. Health Inspector
Chamarajpet
B.B.M.P.

Signature with Seal: Bengaluru West Zone

Name : Bathiyappa

Designation : Assistant Health Inspector

Name & Address of the Office/Department B.B.M.P. West Zone Bengaluru.

To:

The Principal

Royale Concorde International School,
No.31, 1st Main Roas, Chamarajpet, Bengaluru-560 018.

(Name & Address of the Institution)



SLN TESTING LABORATORY

An ISO 9001:2015, ISO14001:2015, ISO 45001:2018

& GLP Certified Laboratory

#23, JDN Layout, 10th Cross, Raghavendra Industrial Area, Thigalarapalya Main Road,
Peenya 2nd Stage, Bengaluru - 560058, Karnataka.

Mob : 9538888098, 9538888097 E - mail: info@slnlabs.com, Web : www.slnlabs.com



TEST REPORT

Page No. 1 of 1

Report No : SLNTL2400400015	Report Date : 04/04/2024
Issued To: M/S. Royale Concorde International School # 31, 1st Main Near Prakash Cafe Chikkapete Bangalore-560018	Customer Reference : Verbal
	Date of Receipt : 01/04/2024
	Date of test start : 01/04/2024
	Date of Completion of test : 04/04/2024
Sample Received By : Customer	Sample Particulars : Borewell Water

Parameters	Results	Maximum Acceptable Limits (in mg/L)	Maximum Permissible Limits (in mg/L)	Test Method
		(As per IS 10500:2012)		
Colour, Hazen Units	<5	5	15	IS:3025/Part-4
Odour	Agreeable	Agreeable	Agreeable	IS:3025/Part-5
Turbidity, NTU	1.1	1	5	IS:3025/Part-10
pH Value	7.20	6.5 – 8.5	No Relaxation	IS:3025/Part-11
Total Hardness as CaCO ₃ , mg/L	303.0	200	600	IS:3025/Part-21
Calcium as Ca, mg/L	64.8	75	200	IS:3025/Part-40
Magnesium as Mg, mg/L	34.4	30	100	IS:3025/Part-46
Chloride as Cl, mg/L	121.0	250	1000	IS:3025/Part-32
Total Dissolved Solids, mg/L	682.0	500	2000	IS:3025/Part-16
Sulphate as SO ₄ , mg/L	28.9	200	400	IS:3025/Part-24
Nitrate as NO ₃ , mg/L	3.0	45	No Relaxation	IS:3025/Part-34
Fluoride as F, mg/L	0.4	1.0	1.5	IS:3025/Part-60
Iron as Fe, mg/L	<0.1	0.3	No Relaxation	IS:3025/Part-53
Total Alkalinity as CaCO ₃ , mg/L	262.0	200	600	IS:3025/Part-23
Total Coli form, MPN/100ml	Not Detected	Not Detectable		IS 1622-1981
E. Coli, MPN/100ml	Not Detected	Not Detectable		IS 1622-1981

Remarks: The given water sample meets to maximum permissible limits as per IS 10500:2012 for above physical, chemical and microbiological testing.

*****End of the Report*****



Authorised Signatory

- Note :
1. The results listed pertain only to the tested samples and applicable parameters.
 2. Samples will be destroyed after 15 days from the date of issue of test certificates unless & otherwise specified and all perishable samples will be destroyed immediately after tests conducted.
 3. This report is not be reproduced either wholly or in part and can not be used an evidence in the count of law and should not be used in any advertising media without prior written permission.
 4. Sampling not done by us, unless specified.